DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials Quality Assurance and Source Inspection

Bay Area Branch 690 Walnut Ave.St. 150 Vallejo, CA 94592-1133 (707) 649-5453 (707) 649-5493



Contract #: 04-0120F4

Cty: SF/ALA Rte: 80 PM: 13.2/13.9

69.28 File #:

WELDING INSPECTION REPORT

Resident Engineer: Pursell, Gary **Report No:** WIR-011088 Address: 333 Burma Road **Date Inspected:** 06-Dec-2009

City: Oakland, CA 94607

OSM Arrival Time: 700 **Project Name:** SAS Superstructure **OSM Departure Time:** 1900 **Prime Contractor:** American Bridge/Fluor Enterprises, a JV

Contractor: Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China

CWI Name: CWI Present: Yes Mr.Du Zhiqun No **Inspected CWI report:** Yes N/A **Rod Oven in Use:** Yes No No N/A N/A **Electrode to specification:** Yes No **Weld Procedures Followed:** Yes No N/A **Qualified Welders:** Yes No N/A **Verified Joint Fit-up:** Yes No N/A N/A Yes N/A **Approved Drawings:** Yes No **Approved WPS:** No Yes No N/A **Delayed / Cancelled:**

34-0006 **Bridge No: Component:** Tower

Summary of Items Observed:

On this date Caltrans OSM Quality Assurance (QA) Inspector, Nagalingam Pandaram Pillai was present during the times noted above for observations relative to the work being performed.

IN PROCESS INSPECTION:-

BAY #10:-

This QA inspector observed the following work in progress:

SMAW welding of weld joint no: ED1-STSA3-2-109M-2-3B located on Strut Plate. Welder is identified as 052493.ZPMC CWI is identified as Mr.Du Zhiqun. The welding variables recorded by QC appeared to comply with the WPS-B-T-2212-TC-U5b.

This QA inspector observed the following work in progress:

SMAW welding of weld joint no: NSTL4-3L/L-4B located on "AB" Corner Seam. Welder is identified as 050289. ZPMC QC is identified as Mr. Jiang Xiao Bo. The welding variables recorded by QC appeared to comply with the WPS-B-T-3211-TC-U4b-1.

This QA inspector observed the following work in progress:

SMAW welding of weld joint no: ND1-A6002-18-21 located on Strut Plate. Welder is identified as 040268.ZPMC CWI is identified as Mr.Du Zhiqun. The welding variables recorded by QC appeared to comply with the WPS-B-T-2113.

BAY #11:-

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

This QA inspector observed the following work in progress:

FCAW welding of weld joint no: ESD1-SPSA4-30-2A located on Interior Corner Splice Assembly Plate. Welder is identified as 040723.ZPMC QC is identified as Mr. Li Jun. The welding variables recorded by QC appeared to comply with the WPS-B-T-2232-B-U5-F.

This QA inspector observed the following work in progress:

FCAW welding of weld joint no: WSD1-SPSA4-5-1B located on Interior Splice Plate. Welder is identified as 040775.ZPMC CWI is identified as Mr. An Qing Xiang. The welding variables recorded by QC appeared to comply with the WPS-B-T-2231-TC-U5-F.

This QA inspector observed the following work in progress:

FCAW welding of weld joint no: WSTL4-2F/L-44 located on Skin "E" Diaphragm to Stiffener Plate. Welder is identified as 040649.ZPMC CWI is identified as Mr. Peng Guo. The welding variables recorded by QC appeared to comply with the WPS-B-T-4333-TC-P4-F.

This QA inspector observed ZPMC qualified welding personnel identified as 049099 perform weld repair on Strut Plate. The WWR Report number is T-WR-2781. SMAW welding of weld joint no: SD1-STSA3-1-89M-1-10A/B. ZPMC CWI Identified as Mrs. Yu Dong Ping. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with the WPS-WPS-485-SMAW-2G(2F)-FCM-Repair-1.

Unless otherwise noted, all work observed on this date appeared to generally comply with the applicable contract documents.

Summary of Conversations:

No Relevant Conversation.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Serge, Sinevod-13482570045, who represents the Office of Structural Materials for your project.

Inspected By:	Pillai,Pandaram	Quality Assurance Inspector
Reviewed By:	Clifford,William	QA Reviewer